

**Certificate Number:** AZ 69026214

Page: 0001



## CERTIFICATE OF SUITABILITY

**Authorised marking:** TUV-026214-E

*TÜV Rheinland Australia Pty Ltd "Electrical Product Safety Certification (EPSC) Scheme", accredited by JAS-ANZ in accordance with ISO/IEC 17065, has issued this certificate under JAS-ANZ accreditation. The electrical equipment described hereunder has been evaluated and found to be electrically safe at the time of certification and met the minimum safety requirements contained in Australian Standard AS/NZS 3820 as of current. It is a requirement that all equipment supplied under this certificate shall be identical to the equipment as certified. The certificate holder may affix the above mentioned authorised marking on the product.*

### CERTIFICATE HOLDER:

GoodWe Technologies Co., Ltd.  
No.90 Zijin Rd., New District  
215011 Suzhou  
P.R. China

### DESCRIPTION OF EQUIPMENT

**Declared class:**

Non-declared

**Product:**

Grid-connected PV Inverter

**Trade Name / Manufacturer:**

GOODWE

**Model Number:**

GW3000-DNS-30 ; GW3600-DNS-30 ; GW4200-DNS-30  
GW5000-DNS-30 ; GW6000-DNS-30

**Ratings:**

Rating details refer to CONTINUATION SHEET 1

**Standard:**

AS/NZS 4777.2:2020+A1  
IEC 62109-1:2010  
IEC 62109-2:2011

**Issue Date:**

27/07/2022

**Expiry Date:**

27/07/2027

*Signed for and on behalf of TÜV Rheinland Australia Pty Ltd*



Grant Li



[www.jas-anz.org/register](http://www.jas-anz.org/register)

**Certificate Number:** AZ 69026214

Page: 0002



## CERTIFICATE OF SUITABILITY

Authorised marking: TUV-026214-E

CONTINUATION SHEET 1

DESCRIPTION OF EQUIPMENT

Ratings:

Protection: Class I, IP66, PD 2 Internal; PD 3 External

Operating Temp.: -25°C to 60°C (>45°C derating)

Overvoltage Category (OVC): PV sides: II; Grid side: III

For models: GW3000-DNS-30; GW3600-DNS-30;  
GW4200-DNS-30; GW5000-DNS-30; GW6000-DNS-30

PV input:

Vmax: 600Vdc

VMPP : 40 - 560Vdc

Isc: 23/23A

Imax: 16/16A

AC output:

Rated Output voltage: L/N/PE, 220/230V

Rated frequency: 50Hz,

Rated Output Apparent power: 3000; 3600; 4200; 5000; 6000VA

Max Output Apparent power: 3300; 3960; 4620; 5500; 6600VA

Rated Output Power: 3000; 3600; 4200; 5000; 6000W

Max / rated Output current: 14.4; 17.3; 20.1; 24; 28.8A

Power factor: 1 (default), 0.80 leading, 0.80 lagging

Issue Date: 27/07/2022

Expiry Date: 27/07/2027

*Signed for and on behalf of TÜV Rheinland Australia Pty Ltd*

A handwritten signature in blue ink, appearing to read "Grant Li", positioned above a horizontal line.

Grant Li



[www.jas-anz.org/register](http://www.jas-anz.org/register)