

Certificate of Conformity

Registered No.:

COCPPV12114/21E-01

File reference
PVP12114/21E-03

Test report No.
TRPVP12114/21E/03

Date of issue
2022-04-25

On the basis of the tests undertaken, the samples of the below product(s) have been found to comply with the essential requirements of the referenced specifications at the time the tests were carried out:

Applicant:	GoodWe Technologies Co., Ltd. No.90 ZiJin Rd., New District, Suzhou, 215011, China
Manufacturer:	GoodWe Technologies Co., Ltd. No.90 ZiJin Rd., New District, Suzhou, 215011, China
Factory 1:	GoodWe Technologies Co., Ltd. No.90 ZiJin Rd., New District, Suzhou, 215011, China
Factory 2:	GoodWe (GuangDe) Power Supply Technology Co., Ltd. No.208, Tong Rui East Road, Guangde, Anhui, China
Product:	Grid-Tied PV Inverter
Type designation:	GW3000-DNS-30, GW3600-DNS-30, GW4200-DNS-30, GW5000-DNS-30, GW6000-DNS-30 Single-phase, Firmware version: V1.00.00
Certification fundamental(s):	BOS-P-01 Rev. 00
Standard(s):	EN 50549-1:2019+AC:2019-04 with deviations according the national network and system protection for Romania See test report for detailed information.

This document is based on the evaluation of the samples of the above mentioned product(s). It does not imply an assessment of the mass-production of the product(s), and it does not permit the use of a TÜV NORD mark. The holder of this document may use it in connection with the related test report(s).